

# FMC Corporation

FMC Wyoming Corporation  
P.O. Box 872  
Green River, WY 82935

307.872.2271 phone  
307.872.2364 fax

June 11, 2008

Dear Valued Customer:

The FMC sodium carbonate (soda ash) products described below have been tested and certified by the National Sanitation Foundation (NSF) as direct drinking water additives. Their use is for pH adjustment and corrosion and scale control. NSF's approval may be viewed by going to the NSF web page at [www.nsf.org](http://www.nsf.org) and conducting a search by manufacturers using the letters FMC. The product listing is under FMC Corporation – Standard 060 – Drinking Water Treatment Chemicals – Health Effects.

	Dosage <u>mg/L</u>
Soda Ash Grades 100,160, 260,	150 max.
Soda Ash Optipro	150 max.
Soda Ash A+	150 max.

The certification continues with the product as long as it remains in its original unopened container from FMC's plant in Green River, Wyoming.

Please contact me at (307) 872-2271 if you have any questions.

Sincerely,



Steve Hickerson  
FMC Corporation

